



PROCUREMENT MANAGEMENT UNIT (PMU)



Taft Ave. cor. Ayala Blvd., Ermita, Manila



(+632) 5317-1768 loc. 738



pmu@pnu.edu.ph

Subject: **BID BULLETIN No. 1**

PROJECT: **Design-and-Build for the Construction of a Three-Storey Gymnasium, Manila Campus**

Date: **July 9, 2026**

This is to inform all the Potential Bidder/s of the following agreements/changes during the Pre-Bid Conference held on July 7, 2026 at Silid Ugnayan, Edilberto P. Dagot Hall.

1. Section VI. Specifications


FROM	TO
V. MECHANICAL WORKS 4. Supply, delivery, and installation of a machine room less Passenger elevator (2 stops, at least 8-person capacity), including accessories and testing and commissioning.	V. MECHANICAL WORKS 4. Supply, delivery, and installation of a machine room less Passenger elevator (3 stops, at least 8-person capacity), including accessories and testing and commissioning.

2. In reference to the query raised during the recent pre-bid conference regarding the total number of air conditioning units required for the project, please refer to the official breakdown provided in the table below:

Item	Room	Capacity	No. of Unit
1.	IT Control Room	1.5 HP	1
2.	Lights and Sounds Control Room	1.5 HP	1
3.	Choir Room	2.5 HP	2
4.	Student Org Room	2.5 HP	2
5.	Art Room	2.5 HP	2
6.	Rondalla Room	2.5 HP	2
7.	Coach/trainer Lounge	2.5 HP	1
8.	Center for Culture and Sports Development Office	2.5 HP	1
9.	Fitness Area	2.5 HP	6
10.	Activity Room	2.5 HP	4

This **Supplemental Bid Bulletin No. 1** shall form part of the Bid Documents (should be included/attached in your Bidding Documents). Any provisions in the Bid Documents inconsistent herewith are hereby amended, modified, and superseded accordingly.

For the information and guidance of all concerned.


DR. LEAH AMOR S. CORTEZ
Chairperson, R-BAC

(All documents without PNU QS Stamp or Control Identifier are uncontrolled)